




KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, MATTANNUR, KOTHERI
WATER ANALYSIS REPORT

Tele phone No : 0490 2993380
email : kwaqualitysdlmattannur@gmail.com

Report No - KWA/QA/R/10/4063/R/89(998)		Date :21/10/2023			
Customer Name and Address SREESANKARA VIDHYAPEEDAM MATTANNUR,MATTANNUR P O PIN:670702 (NONDOMESTIC PURPOSES)	1. Date of receipt	:19.10.2023			
	2. Sampling provided by	Customer (QUA_89816)			
	3. Sample Code	: 01/23 (4063)			
	4. Source of Sample	:Open Well			
	5. Sample quantity	100 ml			
	6. Test performing dates	From: 20/10/2023 To: 21/10/2023			
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185 : 2016; ISO 93081: 2014	Nil	NIL
2	E.Coli	CFU /100 ml	IS 15185 : 2016; ISO 93081: 2014	Nil	NIL

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory


Reviewed & Authorised By
Bacteriologist
BACTERIOLOGIST
QUALITY CONTROL SUBDISTRICT LAB MATTANNUR
KERALA WATER AUTHORITY
KOTHERY, MATTANNUR - 670 702

* End Of Report*

KWA/QC/SDL/MTR/R/17

Issue No: 02

Issue Date : 02.05.2023

Rev No: 01

Rev Date

:02.05.2023

Page 1 of 1